

**ASSEMBLY & INSTALLATION INSTRUCTIONS**

**Fixture**

BPD21203L/21205L/21214L/21223L/21213S/21225S/21241S

---



Schonbek, 61 Industrial Blvd, Plattsburgh, New York, 12901  
Phone: 1-800-836-1892 | Fax: 518-563-4228 |  
[www.schonbek.com](http://www.schonbek.com)

## ASSEMBLY & INSTALLATION INSTRUCTIONS

Fixture  
BPD21203L/21205L/21214L/21223L/21213S/21225S/21241S



- WARNING**  
**IMPORTANT:** NEVER attempt any work without shutting off the electricity.
- o Read all instructions before installing.
  - o System is intended for installation in accordance with the National Electrical Code (NEC), other applicable installation code(s) and local regulations by a licensed electrician familiar with the operation of the product and the hazards involved.
  - o Go to the main fuse box, or circuit breaker panel. Place the main power switch in the "OFF" position and unscrew the fuse (s) or switch "OFF" the circuit breaker switch (es) that control the power to the fixture (s) or room that you are working on.
  - o Place the wall switch in the "OFF" position.
  - o FAILURE TO INSTALL THIS FIXTURE IN ACCORDANCE WITH THESE INSTRUCTIONS MAY RESULT IN SERIOUS PERSONAL INJURY OR DEATH AND/OR PROPERTY DAMAGE.


- CAUTION**
- o All parts must be used as indicated in these instructions. Do not substitute any parts, leave parts out, or use any parts that are worn out or broken. Failure to follow this instruction could invalidate the ETL/CETL Listing of this fixture.
  - o When handling the fixture, do not apply pressure to the LEDs or bulbs. Hold the fixture by the base only.
  - o Do not exceed maximum wattage noted on the fixture. Use only the recommended LED or standard lamps with the fixture.

- ADVERTENCIA**  
**IMPORTANTE:** NUNCA trate de hacer ningún trabajo sin desconectar la electricidad.
- o Lea todas las instrucciones antes de instalar.
  - o El sistema tiene por objeto la instalación de acuerdo con el Código Eléctrico Nacional, y otros códigos de instalación y reglamentos locales aplicables, por parte de un electricista autorizado que esté familiarizado con el funcionamiento del producto y los peligros involucrados.
  - o Vaya a la caja de fusibles o al panel de disyuntores principal. Ponga el interruptor principal de alimentación en la posición de "APAGADO", y desconecte los fusibles o "DESCONECTE" los disyuntores que controlen la alimentación a los dispositivos o la habitación en los que usted está trabajando.
  - o Ponga el interruptor de pared en la posición de "APAGADO".
  - o EL HECHO DE NO INSTALAR ESTE DISPOSITIVO DE ACUERDO CON ESTAS INSTRUCCIONES PODRÍA RESULTAR EN UNA LESIÓN PERSONAL GRAVE O LA MUERTE, Y/O DAÑOS A LA PROPIEDAD.


- PRECAUCIÓN**
- o Todas las piezas deben usarse como se indica en estas instrucciones.No sustituya ninguna pieza, no deje piezas fuera, ni utilice ninguna pieza que esté desgastada ni rota. El hecho de no seguir estas instrucciones podría invalidar la certificación ETL/CETL de este dispositivo.
  - o Al manipular el dispositivo, no aplique presión a los LED ni las bombillas. Sujete el dispositivo solo por la base.
  - o No exceda la potencia máxima indicada en el dispositivo. Use solo los LED o las bombillas estándar recomendados con el dispositivo.

- ADVERTENCIA**  
**IMPORTANTE:** NUNCA trate de hacer ningún trabajo sin desconectar la electricidad.
- IMPORTANT :** Ne JAMAIS entreprendre des travaux sans couper l'électricité.
- o Lire toutes les instructions avant l'installation.
  - o Ce système est conçu pour être installé conformément au Code national de l'électricité ou d'autres codes d'installation et réglementations locales en vigueur par un électricien agréé connaissant le fonctionnement de ce produit et les dangers qu'il comporte.
  - o Aller à la boîte à fusibles ou panneau principal de disjoncteurs. Placer l'interrupteur d'alimentation principal sur « ARRÊT » et dévisser le ou les fusibles ou mettre sur « ARRÊT » le ou les disjoncteurs qui contrôlent l'alimentation du ou des appareils électriques ou de la pièce dans laquelle vous travaillez.
  - o Mettre l'interrupteur mural sur « ARRÊT ».
  - o NÉGLIGER D'INSTALLER CET APPAREIL CONFORMÉMENT À CES INSTRUCTIONS RISQUE D'ENTRAÎNER DE GRAVES BLESSURES PERSONNELLES OU LA MORT AINSI QUE DES DOMMAGES MATÉRIELS.
  - o MISE EN GARDE
  - o Toutes les pièces doivent être utilisées comme indiqué dans ces instructions. Ne remplacer aucune pièce, ne laisser aucune pièce de côté ou n'utiliser aucune pièce usée ou cassée. Le non-respect de cette directive peut invalider l'homologation ETL/CETL de cet appareil.
  - o Lors de la manipulation de cet appareil, n'appliquer aucune pression sur les DEL ou les ampoules. Maintenir l'appareil par la base uniquement.
  - o Ne pas dépasser le nombre de watts maximum indiqué sur l'appareil. N'utiliser que les DEL ou ampoules standard recommandées dans cet appareil.


BPD21203L




BPD21205L



BPD21214L



BPD21223L



BPD21213S



BPD21225S



BPD21241S





## ASSEMBLY & INSTALLATION INSTRUCTIONS


Fixture  
BPD21203L/21205L/21214L/21223L/21213S/21225S/21241S




### Ceiling Plate Dimensions




BPD21214L




BPD21225S



BPD21223L



BPD21241S




## ASSEMBLY & INSTALLATION INSTRUCTIONS

### Fixture

BPD21203L/21205L/21214L/21223L/21213S/21225S/21241S



**Fig. 2 Wire Diagram**




## ASSEMBLY & INSTALLATION INSTRUCTIONS

### Fixture


BPD21203L/21205L/21214L/21223L/21213S/21225S/21241S



**Fig. 3 Wiring**



**Fig. 4 3CCT Switch**



### Product Weight

Product Number	Weights (lbs)
BPD-21203L	21
BPD-21205L	28
BPD-21214L	67
BPD-21223L	113
BPD-21213S	65
BPD-21225S	127
BPD-21241S	208

### HARDWARE

- |                                     |                           |                                   |                                 |                                   |
|-------------------------------------|---------------------------|-----------------------------------|---------------------------------|-----------------------------------|
| A                                   | B                         | C                                 | D                               | E                                 |
|                                     |                           |                                   |                                 |                                   |
| P3 Wire Connector<br>Qty: 3+1 Extra | Canopy Screw<br>Qty: 1 pc | Plastic Anchor<br>Qty: 16+1 Extra | Anchor Screw<br>Qty: 16+1 Extra | 3CCT Switch Cover<br>Qty: 1 Extra |


## ASSEMBLY & INSTALLATION INSTRUCTIONS

### Fixture

BPD21203L/21205L/21214L/21223L/21213S/21225S/21241S

SCHONBEK  
*Beyond*

**Fig. 1**



## ASSEMBLY & INSTALLATION INSTRUCTIONS

### Fixture

BPD21203L/21205L/21214L/21223L/21213S/21225S/21241S

SCHONBEK  
*Beyond*

#### PREPARATION

1. Shut off the power at the circuit breaker and remove existing fixture, including the crossbar.
2. Carefully unpack your new fixture and lay out all the parts on a clear area. Be careful not to lose any small parts necessary for installation.
3. Use gloves when handling trim, crystals, and glass components during installation.  
**Note:** Recommended to use UL approved 200LB max outlet box and hardware (sold separately). If standard duty JB is used, make sure adding adequate fastening to secure the fixture to carry the weight. See weight table below.

#### MOUNTING CEILING PLATE (Fig. 1)

3. Remove the canopy screw (B) from the fixture. Remove the ceiling plate from the canopy.
4. Set color temperature at this stage. The fixture can switch between three color temperatures (3000k, 3500k, 4000k), which can be adjusted to your preference using the 3CCT switch (Fig. 4) mounted in the canopy as shown in Fig. 1.  
(E) All switches must be set on the same setting.  
**Note:** the switch comes with a detachable cover, remove the cover prior to adjusting the color temperature, reattach the cover after adjustment is made.
5. Using the ceiling plate as a template, drill holes in the ceiling aligned with the outer set of holes located in the ceiling plate. Insert the plastic anchors (C) into the ceiling.
6. First, secure the ceiling plate to the junction box using the junction box screws. Second, fasten the ceiling plate to the ceiling using anchor screws (D).
  - (i) It is recommended to use only original junction box screws or replacements provided by junction box manufacturer.
  - (ii) The side of the ceiling plate marked "GND" must face down, towards the installer.
7. Adjust each of the suspension cable lengths by pushing up on the cable gripper on the canopy and pulling the cable through the cable gripper.
  - (i) Adjust the cable lengths to be close to the desired suspension lengths before proceeding.

#### WIRING AND HANGING FIXTURE (Fig. 1, Fig. 2, Fig. 3)

8. Raise the fixture and bring the canopy near the ceiling plate. Attach the fixture to the ceiling plate using a safety cable as shown (Fig. 1).
9. Connect the driver input wires to junction box as shown in Fig. 3. Making sure that all wire connectors (A) are secured. Connect the fixture's ground wire to the ground in the junction box; this will be either a green wire or a bare copper wire. After wires are connected, tuck them carefully inside the junction box.
10. If using a dimmer with this fixture, wire dimmer connections at this stage per section titled "**(OPTIONAL) DIMMER WIRING.**"
11. Raise the fixture and mount the canopy to the mounting plate. Fasten the canopy to the mounting plate using the canopy screws (B).
12. Turn on power to test the fixture.

#### INSTALL DECORATIVE CRYSTAL (Fig. 1)

13. Thread the crystals into the hanging sockets. Adjust the hanging height of the sockets as desired, using the cable grippers at the canopy.

#### (OPTIONAL) DIMMER WIRING (Fig. 2)

- This fixture features electronic low voltage (ELV or TRAC) or 0-10V dimming capabilities. See notes below for specific dimming wires information.
- To utilize ELV or TRAC dimming: use wires black (live), white (neutral) and house green wire or bare copper wire (ground). Do not use dimmer wires on driver for ELV or TRAC dimming.
- To utilize 0-10V dimming: use wires purple (dim+), Pink or gray (dim-) from driver and connect to corresponding wires in junction box.